

# Contents

---

---

Vol. 73, No. 2, 2026

---

---

## Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment

A New Concept of a Power Generating Facility with Integrated Carbon Dioxide Capture  
and Cryogenic Energy Storage

*A. A. Kosoi, A. V. Krysov, O. S. Popel', and S. P. Filippov* 3

---

## Steam Boilers, Power Plant Fuels, Burners and Boiler Auxiliary Equipment

An Analysis of the Results of Studying the Separation of Particles in the Upper Part  
of CFB Apparatuses

*G. A. Ryabov and O. M. Folomeev* 15

Recycling of Coal Preparation Plant Production Waste to Obtain Fuel Briquettes

*K. Yu. Ushakov, E. A. Ereemeev, and E. Yu. Temnikova* 26

---

## Heat and Mass Transfer and Properties of Working Fluids and Materials

The Influence of Flow Restrictor of Water Boiling Heat Transfer on a Finned Surface

*P. G. Bobylev, A. V. Pavlov, S. V. Andreiko,  
V. Yu. Mityakov, and S. Z. Sapozhnikov* 34

Calculation Relationships for Determining the Sizes of Separation Bubbles Generated  
on Perforated Sheets Having Different Geometrical Parameters  
and with Different Two-Phase Layer Heights

*V. A. Devyanin* 45

Assessments of the Hydrogen–Air Mixture Catalytic Combustion Domain  
in a Laminar Flow Regime

*V. A. Fedorenko, V. V. Lemanov, V. V. Lukashov,  
A. V. Tupikin, and K. A. Sharov* 60

Numerical Study of the Tube Effect on Natural Convection in an Inter-Plate Channel

*O. Odintsov, A. B. Garyaev, and A. A. Arbatskii* 66

---

## Nuclear Power Plants

Models and Validation Results of the TRITIUM Module Used as Part of the EUCLID/V2  
Integrated Code for Calculating the Tritium Behavior in Lead Cooled Fast Reactor Systems

*M. V. Vorivonchik, D. A. Nazarov, D. S. Sinitsyn, N. A. Mosunova,  
A. A. Sorokin, A. S. Anikin, and A. N. Bukin* 77

---

---

# A New Concept of a Power Generating Facility with Integrated Carbon Dioxide Capture and Cryogenic Energy Storage

A. A. Kosoi<sup>a, b</sup>, A. V. Krysov<sup>a, \*</sup>, O. S. Popel<sup>a</sup>, and S. P. Filippov<sup>c</sup>

<sup>a</sup> *Joint Institute for High Temperatures of the Russian Academy of Sciences (JIHT RAS), Moscow, 125412 Russia*

<sup>b</sup> *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

<sup>c</sup> *Energy Research Institute of the Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia*

*\*e-mail: a.v.krysov@gmail.com*

**Abstract**—The article presents the concept of a combined cycle turbine unit based on the innovative thermodynamic cycle developed at the Joint Institute for High Temperatures of the Russian Academy of Sciences (JIHT RAS) with integrated carbon dioxide (CO<sub>2</sub>) capture and cryogenic energy storage. The developed cycle relates to the class of semi-closed cycles, but retains all advantages of open and closed cycles. Owing to a wide range in which the power unit electrical and thermal power outputs can be adjusted, units implemented on the basis of the JIHT RAS thermodynamic cycle can efficiently participate in covering the electric and thermal load curves. Owing to the use of working fluid initial components (fuel, oxidizer, and ballasting carbon dioxide and water) in liquid state, it becomes possible to do without compressor equipment and replace it with pumps, thereby reducing energy consumption for plant auxiliaries and decreasing the required capital outlays. Due to the use of oxygen fuel combustion, it becomes possible to implement integrated carbon dioxide capture and prevent its emission into the atmosphere almost completely. Owing to the fact that the heat releasing during steam condensation and the carbon dioxide generated during fuel combustion both return into the cycle, it becomes possible to achieve extremely high efficiency of using the fuel energy in the plant (95% or higher with the plant operating in the cogeneration mode). Owing to the availability of large volumes of cryogenic liquids (air separation products and liquefied natural gas), it becomes possible to implement, on their basis, integrated energy storage based on the phase transition energy. Since cryogenic liquids and equipment for obtaining them are integral components of the power unit process circuit, this makes it possible to compensate for the drawbacks inherent in the cryogenic energy storage method. As a result, a dual effect can be obtained in one unit: carbon dioxide capture and energy storage. The presented combined cycle turbine unit on the basis of the JIHT RAS cycle opens possibilities for retaining large-scale use of organic fuels with simultaneously solving the economy decarbonization problems.

**Keywords:** decarbonization, JIHT RAS thermodynamic cycle, combined cycle turbine, combined cycle turbine unit, integrated carbon dioxide capture, cryogenic energy storage, combined electricity and heat generation

# An Analysis of the Results of Studying the Separation of Particles in the Upper Part of CFB Apparatuses

G. A. Ryabov<sup>a, \*</sup> and O. M. Folomeev<sup>a</sup>

<sup>a</sup> *All-Russian Thermal Engineering Institute, Moscow, 115280 Russia*

<sup>\*</sup>*e-mail: georgy.ryabov@gmail.com*

**Abstract**—Matters concerned with the motion of solid particles in circulating fluidized bed (CFB) apparatuses are considered. It is shown that a significant portion of particles does not enter the cyclones and returns into the furnace, thereby producing an internal circulation loop. The particle capturing efficiency, i.e., the downward to the upward flow rate ratio, depends on the geometrical parameters at the furnace outlet to the cyclone and on the physical characteristics that can be expressed in terms of the Stokes number. The ratio of the outlet port area to the furnace or CFB reactor area is the most important parameter. It has been shown that in analyzing and comparing data, it is also necessary to take into account other geometrical indicators, such as possible influence of density and mass flows, as well as methods for determining them. Measured upward flow rate values, as for example those obtained in the authors' own experiments, can be the most representative ones. The experimental data obtained at the All-Russian Thermal Engineering Institute (VTI) under different flow outlet conditions from furnace models were analyzed. The upward and downward mass flow rates near the outlet port and the flowrate of circulating material captured in the separator are compared. The authors' own studies have shown that the average size of sand particles increases to some degree with increasing the air velocity. Therefore, all previously obtained results were recalculated in this study with taking into account the updated upward flow rate and decrease in the particle sizes at low gas velocities, and compared with the experimental and calculated data reported in the literature sources. The values the authors obtained on the test bench facility with a cross section of  $0.4 \times 0.4$  m lie by approximately 20–30% below the calculated values. The same also relates to other conditions of flow outlet from the furnace, except for the data on the boiler and data at which the calculated values are very close to the experimental ones. A correction of the calculation relationship is proposed.

**Keywords:** circulating fluidized bed, hydrodynamics, particle upward and downward flows, particle separation in the furnace upper part, cyclones, separators, boilers

# Recycling of Coal Preparation Plant Production Waste to Obtain Fuel Briquettes

K. Yu. Ushakov \*, E. A. Ereemeev<sup>a</sup>, and E. Yu. Temnikova<sup>a</sup>

<sup>a</sup> T.F. Gorbachev Kuzbass State Technical University, Kemerovo, 650000 Russia

\*e-mail: ushakovkju@kuzstu.ru

**Abstract**—The article considers a pressing problem of recycling coal sludge (cake), which is one of the main production waste kinds generated in the course of coal preparation. According to assessments, the annual amount of cake generated in Russia makes around 300–650 thousand t. The study considers the prospects for making fuel briquettes from cake without the addition of binding substances, but with the use of wood sawdust as a component absorbing moisture from the surface of cake particles. Such component is necessary because in molding a briquette in the mold, the water phase separates from the cake. The technical characteristics of wet coal cake produced at the Severnaya Coal Preparation Plant (CPP) operated by the Northern Kuzbass Coal Company were determined: the cake moisture content is 44.71%, yield of volatiles is 14.3%, ash content is 47.35%, and higher heating value is 17.67 MJ/kg. With due regard to the experimental and theoretical study results, briquettes from cake are made without additional thermal drying, which have a mechanical drop strength of not lower than 95% and meet the transportation requirements. Formulations for briquetting are selected, and the relationship between the cake moisture content and the required amount of moisture absorbing component is shown. In the case of using cake with the initial moisture content that has not been subjected to pre-drying, it is recommended to use the composition with the cake to sawdust ratio equal to 95/5 wt %. With such composition, the briquettes have the minimal content of sawdust, due to which they feature an increased ash content of 42–45% and a moderate yield of volatiles of 17.3–18.5%. It is shown that mold preheating to 80–100°C helps make briquettes less prone to deformation when subjected to a mechanical impact. The obtained fuel briquettes can be used in the power industry and in public utilities as fuel for boiler facilities and household furnaces.

**Keywords:** coal preparation plant waste, cake, briquetting, waste recycling, filter cake, wood sawdust, fuel briquettes, moisture absorbing component, coal sludge

# The Influence of Flow Restrictor of Water Boiling Heat Transfer on a Finned Surface

P. G. Bobylev<sup>a, \*</sup>, A. V. Pavlov<sup>a</sup>, S. V. Andreiko<sup>a</sup>, V. Yu. Mityakov<sup>a</sup>, and S. Z. Sapozhnikov<sup>a</sup>

<sup>a</sup> Peter the Great St. Petersburg Polytechnic University, St. Petersburg, 195251 Russia

\*e-mail: pavel\_b.g.97@mail.ru

**Abstract**—The article presents the results of studying of heat transfer during pool boiling of saturated water on a finned surface. The experiment involved certain difficulty in view of lack of primary transducers that would help perform direct measurement of local heat flux. A new model of a heterogeneous gradient heat flux sensor was used, which was installed under the heat transfer surface. By using this sensor, the limit boiling heat flux was determined both on a free finned surface and on a finned surface with a flow restrictor. Modern methods for cooling power electronic devices are briefly reviewed. The choice of devices applied in the study is substantiated. The article presents a description of the experimental facility that makes it possible to study heat transfer during boiling of various coolants near surfaces having different geometrical parameters. A solution according to which the thermocouples are placed under the heat transfer surface for correctly representing the heat flux determination results depending on the change in the temperature of the modeled power module is substantiated. The relative standard temperature and heat flux measurement uncertainties did not exceed 2 and 4%, respectively. The flow restrictor application efficiency was estimated. It has been shown that a flow restrictor installed near the surface helps remove steam–water mixture from the heating surface more intensely, due to which the removed heat flux is increased by 35%. The best effect is obtained from using a flow restrictor on surfaces with a distance between the fins close to twice the capillary distance. In addition, by changing the gap in installing the restrictor, it is possible to adjust natural circulation of liquid and control both the removed heat flux and the power module temperature. The obtained results give grounds to believe that further studies in this area should be carried out.

**Keywords:** gradient thermometry, heterogeneous gradient heat flux sensors, local heat flux, immersion cooling systems, finning, boiling heat transfer on nonisothermal surfaces, control of power electronics temperature operation conditions

# Calculation Relationships for Determining the Sizes of Separation Bubbles Generated on Perforated Sheets Having Different Geometrical Parameters and with Different Two-Phase Layer Heights

V. A. Devyanin\*

*National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

*\*e-mail: slava.devyanin@gmail.com*

**Abstract**—Perforated sheets have found wide use in devices installed at thermal and nuclear power plants, and at chemical and petroleum and gas industry enterprises as submersed steam or gas distribution devices, and devices for gas phase dispersion into a low layer of liquid above them, in which processes of heat and mass transfer, or removal of finely dispersed droplet moisture from steam take place. For modeling the hydrodynamic processes occurring in a two-phase layer, it is important to be able to evaluate the average diameter of bubbles generated at the perforated sheet holes and the distribution of these bubbles in terms of their sizes depending on the two-phase medium physical properties, perforated sheet geometrical sizes, and two-phase layer height. However, despite numerous investigations, there are still no experimentally verified formulas for determining the sizes of bubbles generated at the perforated sheet holes at the gas velocities typical for industrial installations and at a small two-phase layer height. The article expands the application domain of their relationships for the separating bubbles generated at single submersed holes, also at a high steam pressure characteristic of devices used in the power industry. In addition, formulas have been proposed for the first time, using which it is possible to calculate the average sizes of separating bubbles and their distribution in terms of sizes for perforated sheets having different geometrical parameters and with different heights of the two-phase layer above them. Experimental data deviate from the calculated values of separating bubble diameters for perforated sheets by no more than 10%, and the average absolute deviations make no more than 3%.

**Keywords:** calculation relationships, perforated sheet, hole diameter, hole relative area, two-phase layer height, bubble generation, separating bubble diameter, bubble distribution in terms of sizes

# Assessments of the Hydrogen–Air Mixture Catalytic Combustion Domain in a Laminar Flow Regime

V. A. Fedorenko<sup>a,\*</sup>, V. V. Lemanov<sup>a</sup>, V. V. Lukashov<sup>a</sup>, A. V. Tupikin<sup>a</sup>, and K. A. Sharov<sup>a</sup>

<sup>a</sup> *Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

*\*e-mail: vitya.fedorenko.335@mail.ru*

**Abstract**—Improving the environmental safety of power facilities is among the top priority problems of the modern science. Conventional energy generation methods on the basis of hydrocarbon fuel are accompanied by significant greenhouse gas emissions. One of promising approaches to reducing the emission is catalytic afterburning, which ensures more complete and controlled fuel oxidation. The article presents a study of heat and mass transfer processes that accompany the streamlining of a flat catalytically active surface by a laminar jet of hydrogen–air mixture directed normally to the surface. With Reynolds number values  $Re < 2000$ , the interaction of an impact jet flowing out from a tube of a length sufficient to produce Hagen–Poiseuille flow was studied. Main attention is paid to evaluating the fuel combustion completeness and determining the chemical activity domain in a laminar regime. The catalyst on the basis of aluminum gamma oxide was modified with rare earth metals and with palladium (Pd) applied on it. As is known, a Stefan flow directed normally to the surface emerges in the course of reactions accompanied by a change in the number of molecules. Comparison with the data reported in the literature shows that chemical reactions running on a palladium catalyst do not have a significant effect on the Sherwood number (Sh) and Nusselt number (Nu). A thermodynamic procedure for evaluating the catalytic reaction domain is proposed, which has been verified with respect to the hydrogen concentration distribution. By using this procedure, it is possible to calculate the Damkohler number proceeding from the temperature profile on the surface, which can be used for determining the catalytic activity for a surface streamlined by a flow of reagents. The developed approach opens the possibility to estimate the minimal sizes of a heat and mass transfer device required for neutralizing harmful substances.

**Keywords:** impact jet, laminar flow regime, hydrogen–air mixture, catalytic combustion

# Numerical Study of the Tube Effect on Natural Convection in an Inter-Plate Channel

I. O. Odintsov<sup>a, b, \*</sup>, A. B. Garyaev<sup>a</sup>, and A. A. Arbatskii<sup>b</sup>

<sup>a</sup> National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

<sup>b</sup> Research Institute for Energy Efficient Microclimate Technologies, Ryazan, 390029 Russia

\*e-mail: OdintsovIO@mpei.ru

**Abstract**—The article presents a numerical study of the effect the diameter of a central tube in the slit-shaped channel between the finned radiator plates has on the heat flux transferred under natural convection conditions. The numerical solution is compared with the calculation carried out according to the Elenbaas formula and with the experimental relationship obtained by Karami et al. It is shown that if there is a tube in the radiator interfin channel, the heat flux transferred under natural convection conditions decreases; the larger the tube diameter, the more significant the heat flux decrease is. This is because of a decrease in the total heat transfer area when there are small relative distances between the fins and a decrease in the air velocity if there is an obstacle. A correction to the Elenbaas formula is proposed for calculating the dimensionless heat transfer coefficient in the slit channel between the radiator vertical plates with a central tube at a constant fin temperature, and the correction application domain is determined. The correction has the form of a power dependence that includes the ratio of heat transfer surface areas with and without the tube, and also such parameters as the tube diameter and fin height, and air density at the temperature of fins and environment. It has been determined that with small tube diameters and distances between the fins, for describing the heat flux in a correct way, it is sufficient to use the formula that takes into account the change in the total heat transfer area. The heat flux values obtained from the calculations carried out according to the proposed relationship differ from the results of calculations carried out using the relationship of Karami et al by no more than 5.5% in the range of central tube diameter to fin height ratios of 0–0.4 and the interfin distance to fin height ratios of 0.03–0.12.

**Keywords:** finned radiator, central tube, fins, heat flux, natural convection, heat transfer, numerical modeling, determination of regularities

# Models and Validation Results of the TRITIUM Module Used as Part of the EUCLID/V2 Integrated Code for Calculating the Tritium Behavior in Lead Cooled Fast Reactor Systems

M. V. Vorivonchik<sup>a, \*</sup>, D. A. Nazarov<sup>a</sup>, D. S. Sinitsyn<sup>a</sup>, N. A. Mosunova<sup>a</sup>,  
A. A. Sorokin<sup>a, \*\*</sup>, A. S. Anikin<sup>b</sup>, and A. N. Bukin<sup>b</sup>

<sup>a</sup> Nuclear Safety Institute (IBRAE), Russian Academy of Sciences, Moscow, 115191 Russia

<sup>b</sup> JSC Academician A.A. Bochvar High-Tech Research Institute of Inorganic Materials (VNIINM), Moscow, 123098 Russia

\*e-mail: vorivonchik.mv@ibrae.ac.ru

\*\*e-mail:sorokin@ibrae.ac.ru

**Abstract**—The article presents the results of developing the models and the TRITIUM software module as part of the EUCLID/V2 integrated code for calculating the migration of tritium and other hydrogen isotopes in the primary circuit of lead cooled fast reactors. Tritium is produced in nuclear fuel; it is radioactive in nature and unlike other radionuclides, can penetrate through the fuel pin cladding and primary circuit pipeline walls into the reactor plant rooms. Hence, it is very important to understand the way in which tritium will behave and propagate to ensure the reactor plant radiation safety. The TRITIUM module incorporates models for the main processes influencing the behavior of hydrogen isotopes in reactor components, including the transfer of isotopes together with the coolant, radioactive decay, penetration through the pipeline walls made of structural materials, degassing from the lead melt, and release of tritium into the reactor plant gaseous loop. To check how correctly the models are implemented in the code by means of software, the article presents the results of verifying the developed module against the data for test problems. The article also presents the code validation results for experiments on the transfer of hydrogen isotopes and their penetration through the pipeline walls made of steels used for the lead cooled reactors designed and constructed in Russia. The presented results demonstrate that the EUCLID/V2 integrated code with the tritium behavior module TRITIUM in the code composition can be used for substantiating the radiation safety of lead cooled reactors and tritium handling systems.

**Keywords:** fast reactor, lead coolant, radionuclides, tritium, hydrogen isotopes, transfer, permeability, accumulation, tritium water