

Contents

Vol. 73, No. 3, 2026

Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment

The JIHT RAS Cycle – a New Approach to Combined Electricity and Heat Generation
with Complete Carbon Dioxide Capture from Combustion Products

*A. A. Kosoi, A. S. Kosoi, A. V. Krysov, O. S. Popel',
M. V. Sinkevich, and S. P. Filippov*

3

Improving the Shell-and-Tube Condenser Design for an ORC Unit Operating on Pentane
as Working Fluid

S. Antanenkova, A. A. Antanenkov, V. I. Kuznetsov, and D. S. Pisarev

17

Determination of Swirl Flow Characteristics in the Laboratory Model
of a Cyclone-Vortex Furnace Extension

K. A. Shtym, T. A. Solov'eva, A. V. Kulik, and E. V. Bazilevich

27

Heat and Mass Transfer, and Properties of Working Fluids and Materials

Control of Bulk Condensation Intensity in a Radial Cooling Turbine Stage by Means
of Frequency Control

A. A. Sidorov and A. K. Yastrebov

34

Numerical Modeling of Heat Transfer during the Flow of Air and Helium–Xenon Mixture
in a Seven-Rod Fuel Assembly

K. S. Lebeda, M. S. Makarov, V. S. Naumkin, and O. V. Vitkovskii

47

Renewable Energy Sources, Hydro Power Engineering

Simulation and Optimization of Heat Pump Water Heater with Wrapped-Tank
Mini-Channel Condenser

Yanjun Li, Heng Liu, Luwen Qin, and Shouhong Li

58

Cogeneration and Heat Networks

Cogeneration: Energy Efficiency of Competing Technologies

S. P. Filippov and M. D. Dil'man

73

The JIHT RAS Cycle – a New Approach to Combined Electricity and Heat Generation with Complete Carbon Dioxide Capture from Combustion Products

A. A. Kosoi^{a, c}, A. S. Kosoi^{a, d, *}, A. V. Krysov^d, O. S. Popel^a, M. V. Sinkevich^a, and S. P. Filippov^b

^a Joint Institute for High Temperatures, Russian Academy of Sciences (JIHT RAS), Moscow, 125412 Russia

^b Energy Research Institute, Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia

^c National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

^d Scientific and Production Association Almaz, Moscow, 127411 Russia

*e-mail: kosoyas@gmail.com

Abstract—The use of power facilities operating on the basis of the innovative thermodynamic cycle developed at the Joint Institute for High Temperatures of the Russian Academy of Sciences (JIHT RAS) opens the possibility of implementing a new approach to determining the list of thermal power plant equipment at the construction stage with ensuring independent control of electricity and heat generation in a wide range, and discarding the use of peaking hot water boilers and peaking electricity generating capacities. The article presents, taking a hypothetical local power system as an example, a comparative analysis of the efficiencies of the proposed and alternative typical versions of supplying heat and electricity to a settlement in Central Russia with a population of half million people. The performed calculation and theoretical investigations have shown that the proposed version features higher thermodynamic efficiency and the possibility of decreasing the annual fuel consumption by 20–30%. The comparison was carried out without taking into account the energy consumption in the alternative versions for capturing the carbon dioxide (CO₂) produced as a result of fuel combustion. The JIHT RAS thermodynamic cycle employs the oxygen fuel combustion technology, and carbon dioxide is removed from the cycle in liquid form convenient for subsequent CO₂ sequestration/disposal. The conventional units will also have to be equipped with an expensive carbon dioxide capturing system and additional energy expenditures for supporting the operation of this system. Owing to the reduced amount of fuel combusted by thermal power plants furnished with the proposed equipment, they will produce a smaller thermal release. With the use of oxygen fuel combustion, the power equipment will not generate nitrogen oxide, which is harmful for human health and detrimental for the Earth ozone layer. Better maneuverability of the proposed equipment and the possibility to operate at deeply decreased partial loads with high thermal efficiency will serve as a pledge for efficient operation of this equipment jointly with facilities on the basis of renewable energy sources (wind and sun).

Keywords: environmentally clean power plant, combined electricity and heat generation, oxygen fuel combustion, carbon dioxide, carbon dioxide sequestration

Improving the Shell-and-Tube Condenser Design for an ORC Unit Operating on Pentane as Working Fluid

I. S. Antanenkova^{a, *}, A. A. Antanenkov^a, V. I. Kuznetsov^a, and D. S. Pisarev^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: antanenkovais@mail.ru

Abstract—Condensing devices constitute quite a bulky—in terms of overall dimensions and metal intensity—part of the thermal process circuit of power facilities implementing the organic Rankine cycle (ORC) during operation on various working fluids. In constructing such devices, it is very important to carry out rational designing, which can help make them with essentially better weight and overall dimension characteristics, and technical and economic indicators. This objective is of special importance for ORC facilities, because there is rather a small amount of commonly accessible information on the optimal structural design of such devices for each capacity level (output) of their equipment. The article presents the results of a computational study aimed at determining the effect the geometrical parameters of finned copper tubes have on the thermal, hydraulic, and mass and overall dimension characteristics of a shell-and-tube condenser for the ORC facility operating on pentane as working fluid for electrical capacities equal to 500 and 1000 kW. In carrying out the analysis, the optimal Rankine thermodynamic cycle parameters and the output of the devices in the nominal mode of their operation were determined. A specific feature relating to the solution of this research problem was the use of a systematic approach to analyzing the distribution of loads among the vapor generator parts (the heater and evaporator) in varying the saturation temperature in it and, hence, in changing the ORC facility efficiency and pentane flowrate. However, the major part of this work deals with the results of variant calculations of the shell-and-tube condenser operating on pentane as working fluid with using GEWA-K tubes produced by Wieland-Werke AG (Ulm, Germany). The calculations were carried out for devices having thermal capacities equal to 2280 and 5560 kW made using tubes having different diameter, wall thickness, and finning, of GEWA-K19, GEWA-K26, and GEWA-K40 types. The article presents the results of a study aimed at determining how the contamination of tube inner surface affects the condenser characteristics: key regularities have been revealed; device optimal design versions have been determined, and recommendations for the developers of the ORC facility shell-and-tube condensers have been formulated.

Keywords: ORC, pentane, shell-and-tube condenser, designing, design optimization, finning, surface contamination

Determination of Swirl Flow Characteristics in the Laboratory Model of a Cyclone-Vortex Furnace Extension

K. A. Shtym^a, T. A. Solov'eva^{a, *}, A. V. Kulik^{a, **}, and E. V. Bazilevich^a

^a Far East Federal University, Vladivostok, 690922 Russia

*e-mail: soloveva.ta@dvfu.ru

**e-mail: kulik_av@dvfu.ru

Abstract—The article describes the laboratory model of an air cooled cyclone-vortex furnace extension (CVFE) for a capacity of around 30 kW, which is a reduced copy of a gas and fuel oil fired CVFE for a capacity of 65 MW, and the operation principles of CVFE assemblies and components are considered. One of the laboratory model features is the possibility to carry out experimental investigations during the gaseous fuel combustion in the furnace extension. Systems for adjusting the height of tangential air nozzles and the position of gas nozzle inlets are implemented for the first time. Unlike industry-grade CVFEs, the laboratory CVFE model is made without refractory lining of the combustion chamber (CC). Owing to this solution, it is possible to estimate the influence of the combustion process on the structural elements and heat transfer conditions in different furnace extension operation modes. Numerous investigations carried out on the laboratory model have demonstrated the possibility to ensure a wide range of CVFE loads and operation mode adjustment. The article presents research modes, in which the static and dynamic pressures, velocity vector direction, and swirl flow temperature were determined using the pneumometric method. The study results are given in graphic form. The variation profile of the full velocity tangential component of the flow swirled in the CVFE model is analyzed. The variations over the CC radius of the profiles of dimensionless tangential velocities and the profiles of dimensionless circulations of swirled flow velocity obtained on the laboratory model and on the industry-grade CVFE are compared with each other. The relative Rossby number Ro of the laboratory and industry-grade CVFEs amounted to 2.67. An analysis of the obtained data of aerodynamic investigations will make it possible to develop new design solutions for the laboratory CVFE model, carry our full-valued fire experiments with it, and in the case of obtaining positive results, introduce the necessary modifications in the industry-grade CVFE.

Keywords: cyclone-vortex furnace extension, combustion chamber, swirl flow, experimental investigations, static and dynamic pressure, gaseous fuel

Control of Bulk Condensation Intensity in a Radial Cooling Turbine Stage by Means of Frequency Control

A. A. Sidorov^{a,*} and A. K. Yastrebov^a

^a National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

*e-mail: AlexSid-MPEI@yandex.ru

Abstract—The study is concerned with numerical simulation of carbon dioxide (CO₂) bulk condensation from its mixture with air in the flow path of a two-phase turbine machine [a turboexpander unit (TEU)] in 3D statement with using a CFD software package and the Bulk Condensation dedicated computation module. The purpose of the study is to determine the effectiveness of frequency control and its influence of the phase transition process in the turbine machine stage. The main objective of the work is to reveal the optimal operation conditions under which moisture droplets emerge and grow predominantly in the impeller channels, which corresponds to the conditions of unlikely erosion destruction of its flow path components. It is shown by calculation that by varying the TEU impeller rotation frequency it is possible to control the bulk condensation process in the radial turbine flow path. The maximal impurity condensation degree—subject to the selected constraints—that can be reached in the flow path makes more than 96% with the maximal expansion ratio equal to 6.17 and the CO₂ content in the mixture flow equal to 10 wt %. It is shown that by comprehensively varying the control parameters (expansion ratio, flow temperature, and impeller rotation frequency) it is possible to adjust the bulk condensation process intensity and also “shift” the phase transition location from the guide vane to the impeller without loss of high condensation degree and particles having sizes minimally acceptable for subsequent separation. It has been found that with increasing the impeller rotation frequency, the condensation intensity in the guide vane decreases quite rapidly, as a consequence of which this process takes place in the impeller, a circumstance that makes it possible to avoid destruction of its components under the effect of droplet impingement erosion. The simulation results are in qualitative agreement with the experimental and calculated data reported in literature sources. As regards quantitative correspondence, its assessment is rather difficult because there is lack of detailed flow path drawings, in view of which it is not possible to carry out numerical simulation.

Keywords: bulk condensation, multiphase flow, CFD, finite volume modeling, kinetic equation, turbine machines, turboexpander, process control, optimization

Numerical Modeling of Heat Transfer during the Flow of Air and Helium–Xenon Mixture in a Seven-Rod Fuel Assembly

K. S. Lebeda^{a, *, **}, M. S. Makarov^a, V. S. Naumkin^{a, b}, and O. V. Vitkovskii^a

^a *Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

^b *Novosibirsk State Technical University, Novosibirsk, 630073 Russia*

**e-mail: kslebeda@mail.ru*

***e-mail: kslebeda@outlook.com*

Abstract—The article presents a study, carried out using numerical methods, of heat transfer during the flow of gas mixtures in a heated seven-rod assembly containing seven cylindrical fuel elements with spacer grids. The fuel elements were made of thin-walled nichrome tubes; owing to a hollow design of fuel elements, it became possible to determine the wall temperature distribution along the assembly length. The grids were made so that all of its channels had the same hydraulic diameters. Helium–xenon (He – Xe) mixture with the Prandtl number $Pr = 0.23$ and air with the Prandtl number $Pr = 0.71$ were considered as coolant. Data on the distribution of the central fuel element wall temperature were obtained, and the effect the spacer grids had on the local changes in the flow parameter and temperature was analyzed. The RANS modeling results were compared with the data of an experimental wall temperature investigation. The comparison results have shown that the predicted data are in good agreement with the experimental data: the maximal difference was equal to 7 K. It was shown that spacer grids gave rise to vortex connection zones upstream and downstream of them; local narrowing of the flow pass section inside the grid facilitated flow acceleration. When a change occurs in the flow dynamics near the grid, abrupt temperature jumps are observed, and it should be noted that air temperature jumps are higher than those of helium–xenon mixture. Thus, in the case of using He – Xe mixture with the Prandtl number $Pr = 0.23$ as coolant, the temperature distribution in the assembly cross section becomes less nonuniform. It is shown that flow acceleration has an influence on the dependence of Nusselt number on the Reynolds number: with high pressure differences between the assembly inlet and outlet, gas accelerates to subsonic velocities, which results in flow core cooling.

Keywords: numerical modeling, heat and mass transfer, helium–xenon mixture, low Prandtl numbers, fuel assemblies, gas cooled reactors, heat transfer downstream of a ledge and obstruction, flow with acceleration

Simulation and Optimization of Heat Pump Water Heater with Wrapped-Tank Mini-Channel Condenser

YanJun Li^a, Heng Liu^b, Luwen Qin^c, and Shouhong Li^{c, *}

^a*Jiangsu Product Quality Testing & Inspection Institute, Nanjing, 210007 China*

^b*Science&Technology Development Center of Jiangsu Provincial Department of Housing and Urban-Rural Development, Nanjing, 210003 China*

^c*School of Energy and Environment, Southeast University, Nanjing, 210096 China*

**e-mail: equart@seu.edu.cn*

Abstract—The application of mini-channel condenser in the field of heat pump water heater (HPWH) introduces new challenges for design and modeling tools, as the two-phase flow mechanisms and flow regime transitions in mini-channel is considerably different from those found in the more conventional larger diameter tubes in the condensing process. Based on the latest research of mini-channel research, this study develops a coupled model that integrates a vapor-compression heat pump model with a water tank heat transfer model, linked through a bidirectional coupling algorithm. In this framework, the heat pump model supplies the tank model with heat flux boundary conditions, while the tank model returns water side parameters to the system model. This coupled approach enables the prediction of both system level performance and the transient hydrodynamics and heat transfer behavior within the water tank, thereby enhancing overall design and analysis capability. Model accuracy is evaluated experimentally using system efficiency, compressor suction and exhaust pressures, condenser inlet and outlet temperatures, evaporating temperature, and water tank temperature measurements. Furthermore, a variable-pitch mini-channel condenser is proposed, and HPWH configurations featuring constant and variable-pitch condensers are simulated. The results demonstrate that the variable-pitch design leads to a more uniform temperature distribution in the tank and yields superior performance in terms of both system efficiency and heat-transfer enhancement.

Keywords: heat pump water heater, wrapped-tank mini-channel condenser, coupled model, variable/constant flat tube spacing, charging process of HPWH

Cogeneration: Energy Efficiency of Competing Technologies

S. P. Filippov^{a, *} and M. D. Dil'man^{a, **}

^a *Energy Research Institute, Russian Academy of Sciences (ERI RAS), Moscow, 117186 Russia*

**e-mail: fil@eriras.ru*

***e-mail: inei1985@mail.ru*

Abstract—The article proposes a methodology for carrying out a comparative analysis of the energy efficiency of combined (cogeneration) and separate arrangements for electricity and heat generation, which takes into account the operating characteristics of different cogeneration unit classes [steam turbine units (STU), gas turbine units (GTU), and combined cycle units (CCU)], as well as the regional climatic conditions of their operation. By using the developed calculation tool, it is possible to determine key indicators such as relative annual fuel saving, coefficient of fuel utilization (CFU), and capacity factor (CF). The study was carried out for a wide range of the capacities of gas units (10–230 MW) and for a coal fired STU (100 MW) with taking into account the characteristics of regional power systems at the places of possible use of cogeneration units. It is shown that cogeneration is an efficient method for saving fuel and reducing greenhouse gas emissions under the currently existing conditions, and with the expected improvement in the efficiency of separate electricity and heat generation. Currently, the use of GTUs and STUs for cogeneration purposes can save 19–37% of fuel, and that of CCUs, up to 28–44% depending on the regional and climatic conditions. Even if we take a hypothetical case of achieving average annual efficiency equal to 55% in the separate arrangement of electricity and heat generation at fossil fueled power plants, the fuel saving due to cogeneration still remains positive, although it will decrease by 1–11% in the case of using steam turbine and gas turbine units, and by 6–19% in the case of using combined cycle units. It has been determined that the best prospects for use will be for cogeneration units featuring high electricity generation efficiency, also during operation at partial loads, and also with a wide thermal power adjustment range. The obtained conclusions and developed techniques can be used for substantiating the choice of technologies in designing and modernizing combined heat and power plants, and in elaborating programs for development of thermal power facilities in regions with different climatic conditions.

Keywords: cogeneration, district heating, combined heat and power plant, energy efficiency, cogeneration unit, combined cycle unit, gas turbine unit, steam turbine unit, boiler house, coefficient of fuel utilization