Contents

Vol. 73, No. 9, 2026

Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment

Development of a Thermal Oil Pentane Evaporator Design for an ORC Unit

M. M. Vinogradov, V. I. Kuznetsov, D. N. Moisin, and I. S. Antanenkova

Influence of Profiling the Curving of the Tip Part of an Unshrouded Blade on Its Aerodynamic Efficiency

A. V. Granovskiy, I. V. Afanasiev, L .I. Bekreneva, and B. I. Kurmanov

Heat and Mass Transfer, and Properties of Working Fluids and Materials

Mathematical Simulation of Compressor Flow Path Inlet Compartments Icing under Adverse Weather Conditions

P. A. Goryachev

Research on Thermal Conductivity of Graphene–Paraffin Composite Phase Change Materials

Qin Wang, Zihua Wu, Haiping Hong, Haoyan Sun, Xiaoxiao Yu, and Huaqing Xie

Renewable Energy Sources and Hydropower

Achieving More Efficient Energy Generation by Complexes on the Basis of Hydropower Resources with the Possibility of Energy Storage during Operation as Part of Autonomous Power Supply Systems

M. A. Biryulin, A. V. Volkov, A. M. Dobrenko, A. A. Druzhinin, and M. O. Sheikin

Automation, Control, and Digital Technologies

Neural Network Simulation of Burner Operation Parameters

M. A. Tarulin, E. P. Kop'ev, and O. V. Sharypov

Condition Monitoring and Diagnosis of a Drum Boiler Using Algorithms of the Paraconsistent Annotated Logic: Condition Monitoring Model of Drum Steam

Ae Chun Ri, Sungjin Kim, Su Gil Kim, Yong Chol Ri, Chol Song Won, and Kwang Myong Kim

Water Treatment and Water Chemistry

Genesis, Morphology, and Composition of Corrosion Product Dissipative Forms in the Primary Coolant of a PWR Type Nuclear Reactor

B. A. Gusev, A. A. Efimov, L. N. Moskvin, and A. N. Maksimova

Development of a Thermal Oil Pentane Evaporator Design for an ORC Unit

M. M. Vinogradov[a], V. I. Kuznetsov[a], D. N. Moisin[a], and I. S. Antanenkova[a, *]

[a] *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

**e-mail: antanenkovais@mail.ru*

Abstract—A vapor generator is among the most complex and thermally stressed component of the thermal cycle circuit of a power unit operating according to the organic Rankine cycle (ORC). As a rule, the ORC unit vapor generators intended for recovering the waste heat in industrial processes are "connected" to the source via an intermediate thermal oil loop. With such an arrangement, thermal oil, which has the maximum possible temperature, enters sequentially first the vapor generator's evaporating and then heating part, in which it transfers heat to the power unit's low-boiling working fluid (LBWF). The study addresses matters concerned with designing the evaporator, in the tubes of which the LBWF is heated to the saturation temperature at a specified pressure, boils, and is superheated prior to be supplied to a turbine (an expansion engine). Oil coolers of stationary power units operating on steam as working fluid are considered as prototypes for design implementation of the ORC unit evaporator: vertical shell and tube devices, including those with smooth tubes, with "disc–ring" type partitions with nonsealed and sealed process gaps, as well as with low knurled fins on tubes, with "disc–ring" type partitions, and sealed process gaps. The article presents the results of a review of experimental data and applicability analysis of existing models for calculating the heat transfer coefficient and critical heat flux for LBWF boiling in tubes, which can be recommended for including them into the device thermal-hydraulic design calculation. The procedure for calculating the pentane evaporator for a thermal capacity of 1440 kW for a 500 kWe ORC unit has been tested. A "field of solutions" has been obtained for the layout versions of the evaporator heat transfer surface composed of tubes made of carbon steel, stainless steel, brass, and copper, having an outer diameter of 10, 12, 14, 16, and 18 mm and wall thickness from 0.5 to 2.5 mm, as well as finned tubes the finning ratio of which was varied from 2.2 to 2.4. By applying correlation analysis methods, a data array on the optimal layout versions of the heat transfer surface for devices of all designs considered has been set up. Recommendations on selecting the design version of a pentane evaporator as part of an ORC unit have been compiled.

Keywords: evaporator, low boiling working fluid, vapor generator, ORC, thermal oil, heat transfer coefficient, boiling in tubes, heat flux, shell-and-tube heat exchanger, pentane, filling

Influence of Profiling the Curving of the Tip Part of an Unshrouded Blade on Its Aerodynamic Efficiency

A. V. Granovskiy[a], *, I. V. Afanasiev[a], L. I. Bekreneva[a], and B. I. Kurmanov[a]

[a] *Lyulka Design Bureau, a branch of PJSC UEC-UMPO, Moscow, 129301 Russia*

**e-mail: andrey.granovskiy@yandex.ru*

Abstract—The development of tip clearance control and monitoring systems in gas turbines has led to a trend toward eliminating shrouds on rotor blades in a number of high-power stationary gas turbines, such as the SGT5-4000F, SGT-8000H, and others. Eliminating shrouds opens the possibility of optimizing turbine parameters, increases the degree of freedom in selecting the number of blades in the rotor, allows the reduction of rotor blades weight and, consequently, reduces the contour load on clearance above the unshrouded rotor blade (RB), which is not always possible, especially in aircraft turbines. To reduce inductive tip losses, several patents propose forming the tip area portion of the rotor blade with a slight curvature of the blade toward the suction surface in the circumferential direction. This minimizes the pressure difference between the pressure and suction surfaces near the blade tip. However, no quantitative estimates of this effect are provided. To obtain quantitative estimates of the impact of blade curvature at the tip area a computational study of the flow structure and energy loss level in the considered region was conducted using state-of-the-art CFD approaches for solving the 3D Navier-Stokes equations in a steady-state RANS formulation. In the first stage of the study, calculations were performed using the proprietary (in-house code) 3D NS software package. However, in the absence of experimental data the validation, justification and visualization of proprietary the numerical results obtained using the 3D NS program, computational studies of the flow in a rotor blade row with an open tip clearance were also conducted with the commercial software packages ANSYS FLUENT and ANSYS CFX. The computational study of the flow structure demonstrated a positive effect of this measure, resulting from a significant reduction in vortex formation zones due to flow in the tip clearance and, consequently, a reduction in losses when the rotor blade tip is tilted toward the suction surface.

Keywords: tip clearance, shroud, blade tip bending, vortex from leakage in the tip clearance

Mathematical Simulation of Compressor Flow Path Inlet Compartments Icing under Adverse Weather Conditions

P. A. Goryachev[a, *]

[a] *Baranov Central Institute of Aviation Motors, Moscow, 111116 Russia*

**e-mail: pagoryachev@ciam.ru*

Abstract—Ice formed on the components of onland power equipment and aircraft equipment under harsh weather conditions adversely affects their operation. Icing may emerge both near the ground surface and at significant altitudes. The article proposes an advanced 3D icing model, which covers a wide range of outdoor conditions (supercooled droplets, dry ice crystals, and a mixture of phases), as well as various icing surface states (dry or moistened, heated or nonheated). Special attention is paid to simulating the processes in the compressor flow path, in particular, to ice formation on dry heated surfaces when a flow of dry ice crystals deposits on them. The model describes conjugate unsteady heat transfer from an object's heated surface to the forming ice crust, which has a complex multilayer inner structure. The ice layer may contain accumulated liquid water. This water can flow over the ice surface in the form of hillocks, rivulets, and films, and in the case of partial melting, cavities filled with liquid water may occur on the heated surface. The results of predicting the ice locations and mass and dimension characteristics are compared with experimental data obtained on the compressor flow path model. It has been confirmed that the interconnected and interrelated physical effects accompanying ice formation, such as heat and mass transfer, the degree to which ice crystals are partially melted in the carrier flow and captured by the ice crust surface, as well as ice erosion, are described in a correct way. In carrying out predictions, a Pi-shaped curve representing the dependence of ice growth rate on the crystals melting degree has been obtained, which is in good agreement with the experimental data.

Keywords: icing, compressor, ice crystals, mixture of phases, finite element method, mathematical simulation

Research on Thermal Conductivity of Graphene–Paraffin Composite Phase Change Materials

Qin Wang[a], Zihua Wu[a, b, *], Haiping Hong[a, b, **], Haoyan Sun[a], Xiaoxiao Yu[a], and Huaqing Xie[a, b]

[a] *School of Energy and Materials, Shanghai Polytechnic University, Shanghai, 201209 China*

[b] *Shanghai Engineering Research Center of Advanced Thermal Functional Materials, Shanghai, 201209 China*

**e-mail: wuzihua@sspu.edu.cn*

***e-mail: hphong@sspu.edu.cn*

Abstract—In this study, the thermal conductivity of paraffin matrix was improved by adding functional graphene. Composite phase change materials (PCMs) based on paraffin and acid-treated graphene were prepared and tested at various treatment temperatures (90, 120, and 150°C) with varying mass fractions of the filler. Preliminary acid treatment of graphene reduced the interfacial thermal resistance and improved the dispersion stability of the filler in the matrix due to the introduction of functional groups onto its surface. The following key characteristics were determined for the obtained samples: dispersion stability of graphene, micromorphological structure, and chemical compatibility of the components. Fourier-transform infrared spectroscopy results showed that graphene treated with acid at 120°C exhibited more pronounced absorption peaks, indicating a higher content of O–H, C=O, and C–O bonds compared to graphene treated at other temperatures. Thermal conductivity measurements of the composite PCM samples at various temperatures revealed that at 60°C, the maximum increase in thermal conductivity (23.2%) relative to pure paraffin was observed for the paraffin composite with 0.1 wt% acid-treated graphene (treated at 120°C). This confirms that the acid treatment temperature of 120°C is optimal. When the mass fraction of graphene in this composite was increased to 0.9%, the thermal conductivity reached 0.314 W/(m · K), which is 49.55% higher than that of pure paraffin.

Keywords: graphene, phase change material, thermal conductivity, acid treatment, paraffin

Achieving More Efficient Energy Generation by Complexes on the Basis of Hydropower Resources with the Possibility of Energy Storage during Operation as Part of Autonomous Power Supply Systems

M. A. Biryulin[a], A. V. Volkov[a], A. M. Dobrenko[a, *], A. A. Druzhinin[a], and M. O. Sheikin[a]

[a] National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

**e-mail: dobrenkoam@mpei.ru*

Abstract—The possibility of achieving more efficient electricity generation by energy complexes on the basis of hydropower resources with predominantly using them in autonomous power supply systems is analyzed. The choice of daily amount of electricity production as a criterion for estimating the energy complex performance is substantiated. Methods for improving the generation efficiency are considered, such as daily load profile optimization, also when there is a buffer energy storage in the power system; combined generation of electricity; extremum seeking control of hydroelectric power units and maneuverable hydroelectric power units in the operation modes of micro pumped storage hydroelectric (microPSH) power plants, as well as electrochemical energy storages, and their combinations. Special attention is paid to extremum seeking control implementation methods for various types of electric generators, which make it possible to increase the daily amount of electricity generated by both newly developed and existing complexes on the basis of hydropower resources without introducing significant changes in the design layout with taking into account stabilization of the autonomous electric network parameters. A new simpler and more accurate extremum seeking control method by monitoring mechanical rather than electrical parameters is proposed. To confirm the theoretical hypotheses on implementing extremum seeking control, field experiment data are given and analyzed, which testify that the proposed method is well grounded and highly efficient in nature. The costs of electricity in using different methods for storing it and for achieving better efficiency of its generation are compared, and versions of their combined use are considered. It has been confirmed that there is a significant potential for achieving more efficient electricity generation with the use of hydropower resources, and practical methods for achieving this aim are described.

Keywords: generation, autonomous power supply, extremum seeking control, microPSH power plant, energy storage, hydropower resources, electrochemical energy storages

Neural Network Simulation of Burner Operation Parameters

M. A. Tarulin[a], *, E. P. Kop'ev[a], and O. V. Sharypov[a]

[a] *Kutateladze Institute of Thermophysics, Siberian Branch, Russian Academy of Sciences, Novosibirsk, 630090 Russia*

**e-mail: tarulin.mark@gmail.com*

Abstract—The article presents the results of studying the applicability of deep learning methods for predicting the operation parameters of a liquid fuel fired burner with steam-assisted atomization and a gas generation chamber, which is intended for combusting low grade liquid hydrocarbon fuels and waste based on a flame visual analysis. The scientific novelty of the study is that with steam-assisted atomization it is possible to obtain visual flame patterns differing from those obtained using conventional methods, for interpreting of which a dedicated approach is required. A modified architecture of the dense convolutional neural network DenseNet-121 is proposed with weights pretrained on the ImageNet data set, which is adapted to solving the regression problem of predicting the device process operation parameters (fuel and superheated steam flowrates). The DenseNet-121 architecturec with dense interlayer connections is able to efficiently draw fine visual features from the flame images, which are critical for establishing the functional dependences. The regression subnetwork includes fully connected layers with the rectified linear unit (ReLU) activation and Dropout regularization. Validation on an independent test sample of experimental data has shown high accuracy of the model: for the fuel flowrate, the mean absolute error (MAE) is 3.8%; the root mean square error (RMSE) is 9%, and the determination coefficient $R^2 = 0.957$; for steam flowrate the MAE is 2.6%; RMSE is 4%, and $R^2 = 0.994$. The achieved results ($R^2 > 0.95$ for both the parameters) confirm that the model is able to catch complex interrelations between the flame visual characteristics and burner operation parameters. The proposed solution is aimed at developing an intellectual tool for prompt contactless monitoring and optimization of liquid fuel combustion processes in burners with steam-assisted atomization and a gas generation chamber.

Keywords: neural network, liquid fuel fired burner, gas generation chamber, steam-assisted atomization, parameter prediction, computer vision, convolutional neural network

Condition Monitoring and Diagnosis of a Drum Boiler Using Algorithms of the Paraconsistent Annotated Logic: Condition Monitoring Model of Drum Steam

Ae Chun Ri[a], Sungjin Kim[b], Su Gil Kim[c,] *, Yong Chol Ri[d], Chol Song Won[a], and Kwang Myong Kim[a]

[a] *Faculty of Applied Mathematics, Kim Chaek University of Technology, Pyongyang, 950003 Democratic People's Republic of Korea*

[b] *Faculty of Automation Engineering, Kim Chaek University of Technology, Pyongyang, 950003 Democratic People's Republic of Korea*

[c] *Institute of Nano Science and Technology Engineering, Kim Chaek University of Technology, Pyongyang, 950003 Democratic People's Republic of Korea*

[d] *Thermal Engineering Faculty, Kim Chaek University of Technology, Pyongyang, 950003 Democratic People's Republic of Korea*

**e-mail: ksg75712@star-co.net.kp*

Abstract—In this work, a condition monitoring model of drum steam using Paraconsistent Annotated Logic (PAL) was investigated to provide the mathematical and logical foundation for the application of PAL to monitor condition of steam in boiler drum. Three methods are proposed in order to calculate evidence degrees from steam pressure and temperature and evaluate steam state in the drum. The Paraconsistent Analysis Node (PAN) takes evidence diagrams as input to analyze and process the inconsistency and uncertainty of signals corresponding to pressure and temperature. The PAN outputs the resultant real evidence degree, the Contradiction Degree and the Normalized contradiction degree. A network of paraconsistent analysis (PANnet) which is combined with these methods is also proposed in order to analyze and treat the contradiction. And based on this, the application of PAL for condition monitoring of drum steam, one of the local systems of the Fault Detection and Diagnosis (FDD) for Thermal Power Plants (TPPs), is demonstrated. For two faults, the fault detection times are reduced by 60 and 64%, respectively, compared to the conventional ones. The condition monitoring and diagnosis of evaporators as well as boiler drum can be improved by using this steam condition monitoring model.

Keywords: paraconsistent annotated logic, network of paraconsistent analysis, pressure, temperature, saturated steam, extractor of evidence degree

Genesis, Morphology, and Composition of Corrosion Product Dissipative Forms in the Primary Coolant of a PWR Type Nuclear Reactor

B. A. Gusev[a], *, A. A. Efimov[a], L. N. Moskvin[a], and A. N. Maksimova[a]

[a] *Aleksandrov Research Institute of Technology, Sosnovy Bor, Leningrad Oblast, 188540 Russia*

**e-mail: gusev@niti.ru*

Abstract—The article considers regularities relating to the behavior of dissipative corrosion product (CP) impurities (solid phase particles) existing in the primary circuit of a test bench serving as a prototype of a nuclear propulsion system as suspensions and deposits. For nuclear power plants (NPPs) equipped with PWR-type reactors, reducing water chemistries (WC) are adopted, including ammonia water chemistry and ammonia-boron-potassium water chemistry with boron control. The relevance of the study is stemming from rapid development of small modular nuclear power plants (SNPPs) in sparsely populated areas of Siberia and Far East. An explanation of the mechanism governing the formation of solid phase corrosion products is proposed. The article presents the results of experiments on studying the morphology, chemical, and radionuclide compositions of CPs formed in making purposeful changes of hydrodynamic, thermophysical, and physicochemical parameters of the primary circuit of a PWR-type reactor operating with an ammonia water chemistry, which may serve to a full extent as a reference one with respect to an SNPP. Owing to the revealed regularities, it became possible to determine the optimal process parameters of reagent-free decontamination. In the case of using the design water chemistry in the primary circuit, the CP composition, the corrosion rate of structural materials, and the content of radionuclides in activated corrosion products (ACPs) are kept at levels ensuring the minimal dose burden on the personnel during the NPP operation. Long-lived radionuclides in ACPs such as ^{60}Co and to a certain extent ^{54}Mn are the main sources causing exposure of the personnel serving the NPP during repair works. In the case of using the ammonia water chemistry, the phase composition of corrosion deposits and suspensions in the coolant is determined, irrespectively of the NPP design features, by nonstoichiometric magnetite spinel, the composition of which includes elements of alloying additions and their activation products. The chemical composition of solid phase corrosion products separated from coolant samples is essentially identical with the composition of Grade 0Kh18N10T steel, which is the coolant circuit main structural material.

Keywords: small modular nuclear power plant, ammonia water chemistry, dissipative solid phase corrosion product forms, formation, morphology, composition