Contents

Vol. 73, No. 10, 2026

Steam Turbine, Gas Turbine, and Combined Cycle Plants and Their Auxiliary Equipment

Results of Elaborating the Demo Model of a Small Turboshaft Gas Turbine Engine and a Power Unit on Its Basis

S. S. Remchukov, A. L. Kozlov, M. A. Danilov, E. A. Polyakov, I. S. Ptitsyn, and I. V. Osipov

Modeling and Thermal Performance Analysis of a Flexible Peak Shaving System for Thermal Power Units Coupled with Molten Salt Energy Storage

Yunpeng Gao, YanSun, Yunlong Zhou, and Rui Liu

Heat and Mass Transfer, and Properties of Working Fluids and Materials

Studying a Submerged Liquid Metal Jet in Longitudinal Magnetic Field Using Hybrid LES Modeling and Experimental Methods

M. A. Sokolov, N. G. Razuvanov, and O. N. Polyanskaya

Effective Thermal Conductivity of a Heat Pipe with Forced Working Fluid Pulsations

E. P. Valueva

Studying the Thermal Characteristics of a Copper Loop Heat Pipe with a Flat Evaporator

A. S. Panasenko, Yu. F. Maidanik, M. A. Chernysheva, and S. V. Vershinin

Verification of a Steam–Gas Mixture Analytical Model at Increased Pressures

A. A. Fal'kov

Renewable Energy Sources, Hydro Power Engineering

Exergy Analysis of Parabolic Trough Collector

Milind S. Patil, Sanjay P. Shekhawat, Ishan M. Patil, Neelkanth G. Nikam, and Chandrashekhar D. Mohod

Water Treatment and Water Chemistry

The Influence of Quantitative and Qualitative Composition of Deposits on the Damageability of High Pressure Boiler Waterwall Tubes

O. V. Egoshina and Alkhatib Diaa

Chemical Blending as a Version for Improving Scale Inhibitors

D. S. Prirez and S. L. Gromov

Errata

Erratum to the article "Comparison of the Virtual Test Results for the Profiling Versions of a High-Capacity Steam Turbine's Low Pressure Cylinder Stages," written by K. L. Lapshin and Yu. V. Ferafont'ev, published in Teploenergetika No. 7, 2026 126

Results of Elaborating the Demo Model of a Small Turboshaft Gas Turbine Engine and a Power Unit on Its Basis

S. S. Remchukov[a, *], A. L. Kozlov[a], M. A. Danilov[a], E. A. Polyakov[a], I. S. Ptitsyn[a], and I. V. Osipov[a]

[a] *Baranov Central Institute of Aviation Motors, Moscow, 111116 Russia*

**e-mail: ssremchukov@ciam.ru*

Abstract—The article presents the results of elaborating a compact small gas turbine power unit relating to the 180 kW capacity class intended for a wide use in various industry branches. The design solutions for and technical characteristics of modern compact power units in the considered class are reviewed and analyzed, based on which a rational configuration of the power unit developed has been shaped. Its design features and advantages reached in implementing the proposed solutions are given. The computation study results were obtained with the use of computer simulation techniques and include the performance indicators of the compressor, turbine, combustor, and the gas generator's rotor supports lubrication and cooling system. After carrying out design optimization, the compressor and turbine adiabatic efficiency values amounted to no less than 83 and 91%, respectively, and the combustor efficiency in the power unit design operation modes was no less than 96%. The design calculations of the bearing supports lubrication and cooling system show that to ensure their sufficient cooling, it is necessary to decrease the temperature of compressed air extracted from the compressor by no less than 100°C. The article presents the data of the rotor unit experimental studies, within the framework of which the effectiveness of an open-loop air–oil lubrication and cooling system of the rotor supports is confirmed, and the minimal oil flowrate sufficient for lubricating the bearings in the operation modes studied is determined. In the course of experimental studies of the fuel system equipped with a motor driven pump, its serviceability is confirmed, and the fuel flowrate nonuniformity through the centrifugal nozzles installed on the fuel manifold is estimated. It is shown that in the case of using single-channel nozzles, the fuel flowrate nonuniformity may reach 48% in various modes, whereas the nozzle with fuel bypass ensures the flowrate nonuniformity equal to 3–7%, a circumstance that should be taken into account in designing the combustor. In the gas generator tests, the mismatch between the data on design operation modes obtained experimentally and by using the mathematical simulation method was less than 5%. A demo model of the developed compact power unit relating to the 180 kW capacity class has been produced.

Keywords: small gas turbine power unit, gas generator, electrification, centrifugal nozzles, fuel system, combustor, fuel flowrate nonuniformity

Modeling and Thermal Performance Analysis of a Flexible Peak Shaving System for Thermal Power Units Coupled with Molten Salt Energy Storage

Yunpeng Gao[a, b], Yan Sun[a, *], Yunlong Zhou[c], and Rui Liu[d]

[a] *School of Energy and Power Engineering, Northeast Electric Power University, Jilin, 132012 China*

[b] *China Electricity Council, Beijing, 100761 China*

[c] *Zhejiang Guangsha Vocational and Technical University of Construction, JinHua, 322100 China*

[d] *School of Automation Engineering, Northeast Electric Power University, Jilin, 132012 China*

**e-mail: sunyan20251118@163.com*

Abstract—To improve the capacity for peak shaving and the renewable energy consumption of the power grid, mining the peak shaving potential of coal-fired units and enhancing unit flexibility are the future development trends for thermal power units. In this paper, a 350 MW supercritical unit as the research object, four molten salt thermal energy storage schemes (Schemes *A*–*D*) are proposed, which differ in the steam extraction point (live steam or steam after reheat) and the return point of the exhaust steam to the thermal cycle, as well as five energy release schemes (Schemes *a*–*e*), which differ in the route of the heated feedwater and its injection point into the cycle. Through thermal balance calculation, the thermal performance and peak shaving capacity of each coupling scheme under five load conditions are compared and analyzed, and the system performance is evaluated by using evaluation indices such as thermal efficiency, peak shaving efficiency, peak shaving depth, and round-trip efficiency. The results show that the molten salt energy storage system significantly improves the operation flexibility of the unit, effectively alleviates the contradiction between the unit load and electricity price, and improves the peak shaving depth and peak capacity of the unit; Under the condition of energy storage, Scheme *B* has the highest thermal efficiency of 49.47%, the remaining three schemes are Scheme *D*, Scheme *A* and Scheme *C* from large to small, the maximum thermal efficiency of Scheme *D* is 44.27%, the maximum thermal efficiency of the remaining three schemes is Scheme *A*, Scheme *B* and Scheme *C* from large to small; under the condition of energy release, Scheme c has the highest thermal efficiency of 41.25%, the remaining four schemes are Scheme *e*, Scheme *b*, Scheme *d* and Scheme *a* from large to small, and Scheme *b* has the highest thermal efficiency of 43.89%; Under the condition of overall energy storage and release; The energy storage scheme is Scheme *B*, and the energy release scheme is Scheme *b*, which has the highest thermal efficiency and thermal efficiency, which are 44.3 and 43.37%, respectively.

Keywords: molten salt energy storage, deep peak shaving, coal-fired units, thermodynamic performance

Studying a Submerged Liquid Metal Jet in Longitudinal Magnetic Field Using Hybrid LES Modeling and Experimental Methods[1]

M. A. Sokolov[a, *], N. G. Razuvanov[a, b], and O. N. Polyanskaya[b]

[a] *Joint Institute for High Temperatures, Russian Academy of Sciences (JIHT RAS), Moscow, 125412 Russia*

[b] *National Research University Moscow Power Engineering Institute (NRU MPEI), Moscow 111250 Russia*

**e-mail: maximsocolov1997@mail.ru*

Abstract—The article presents the results of numerically simulating a submerged jet flow of liquid metal (mercury) in a round tube under the effect of longitudinal magnetic field. The submerged jet is produced when liquid metal flows out from a small diameter tube with $d_1 = 5$ mm into a coaxial tube of a larger diameter $d_2 = 25$ mm. The numerical study was carried out using the ANES computer code, which implements the hybrid large eddy simulation method KDES. In the study, the regime in which turbulent flow takes place in a jet, and laminar flow takes place at the outlet from the larger diameter tube was simulated. The simulations were carried out for the Reynolds number Re = 10 000 and Hartmann numbers in the range Ha = 0–125. The simulation results are compared with the experimental hydrodynamic data on a submerged liquid metal jet obtained on the mercury test bench at the NRU MPEI under conditions close to the simulated ones. In the experiment, the time-averaged velocity fields were measured according to the probe technique with the use of a four-thermocouple probe. The probe contained a correlation pair (for measuring the velocity longitudinal component) and two conduction pairs (for measuring the transverse and azimuthal components). The simulation results are on the whole in agreement with the experimental data. The effect in which longitudinal magnetic field suppresses the absolute velocity pulsation level has been confirmed. It has been determined that with increasing the Hartmann number, the jet width decreases with distance from the edge, while its effective length increases. At the same time, it has been found in the experiment that the jet becomes swirled under the effect of longitudinal magnetic field, a phenomenon that was not replicated in the simulations.

Keywords: liquid metals, magnetic hydrodynamics, probe measurements, velocity pulsations, jet flow, hybrid LES method, ANES computer code

Effective Thermal Conductivity of a Heat Pipe with Forced Working Fluid Pulsations

E. P. Valueva*

National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia

**e-mail: ep.valueva@gmail.com*

Abstract—The effective thermal conductivity of a pulsating heat pipe (also referred to as a dream pipe) is studied. In heat pipes of this type, longitudinal heat transfer is enhanced owing to forced working fluid pulsations. The operating parameters on which the solution of the problem depends are determined: the thermal Womersley number Wo_{tl} determined based on the tube length l and the relative pulsation amplitude $k_x = \tilde{x}_m/l$, where $\tilde{x}_m$ is the pulsating liquid layer longitudinal displacement amplitude. The heat pipe operation modes are classified. In the case of pulsations with high amplitudes $k_x \gg 1$, the quasi steady state heat transfer mode takes place. For this mode, the analytical solution of the energy equation averaged over the pipe cross section is obtained. The solution of the problem depends on the Peclet number Pe_{lm}, determined proceeding from the amplitude of longitudinal velocity harmonic pulsations and pipe length. It has been found that at high Peclet numbers, the effective thermal conductivity to the immobile liquid layer thermal conductivity ratio Λ increases in proportion to Pe_{lm}. In the general case, the equation of energy was solved using the finite difference method with applying a newly developed unconditionally stable difference scheme. For practical use of calculation results, the indicator Λ is represented as a dependence on the thermal Womersley number Wo_t and dimensionless longitudinal displacement $\Delta X = \tilde{x}_m/h$ (where h is the channel hydraulic radius). The pulsating heat pipe efficiency η has been calculated, which is defined as the ratio of thermal power transmitted in the longitudinal direction to the power required to excite forced working fluid pulsations. It is shown that under quasi steady state hydrodynamic conditions the coefficient η reaches high values. The pulsating heat pipe optimal parameters have been estimated.

Keywords: pulsating heat pipe, forced pulsations, effective thermal conductivity, efficiency, thermal Womersley number, relative pulsation amplitude

Studying the Thermal Characteristics of a Copper Loop Heat Pipe with a Flat Evaporator

A. S. Panasenko[a], *, Yu. F. Maidanik[a], M. A. Chernysheva[a], and S. V. Vershinin[a]

[a] *Institute of Thermal Physics, Ural Branch, Russian Academy of Sciences, Yekaterinburg, 620016 Russia*

**e-mail: panasenko@itpuran.ru*

Abstract—The article presents the results of experiments aimed at studying the thermal characteristics of a copper loop heat pipe (CHP) with a newly designed flat evaporator and a U-shaped tubular condenser. Water and methanol were used as coolants. The tests were carried out on the horizontally oriented device with heat sources that had the heating surface areas equal to 25 and 35 cm^2. The flowrate of thermostatically controlled condenser cooling water was equal to 3.6 dm^3/min, and its temperature at the inlet was equal to 20 and 40°C. The minimum thermal resistance of the evaporator with water equal to 0.017 °C/W was achieved when using the heat source with an area of 35 cm^2 at a thermal load equal to 600 W, which was limited only by the heater power. The temperature on the heat source heating surface was in that case equal to 79.5°C. The minimum thermal resistance of the evaporator with methanol was equal to 0.019 °C/W at the heat load equal to 300 W and heat source temperature equal to 86.4°C. The minimum thermal resistance of the evaporator with water and the heat source with an area of 25 cm^2 was equal to 0.024 °C/W at the heat load equal to 900 and temperature equal to 105.7°C. In the case of using methanol, the following values were obtained: 0.022 °C/W at 300 W and heat source temperature equal to 86.4°C. The results of the presented LHP development and study results may be used, in particular, in designing the cooling systems of the functional components of powerful electronic devices, such as e.g. central and graphic processors used in the computer servers installed at data centers.

Keywords: electronic device cooling system, loop heat pipe, evaporator, condenser, heat load, thermal resistance, heat source

Verification of a Steam–Gas Mixture Analytical Model at Increased Pressures

A. A. Fal'kov*

Afrikantov Experimental Design Bureau for Mechanical Engineering (OKBM) Nizhny Novgorod, 603074 Russia
**e-mail: okbm@okbm.nnov.ru*

Abstract—The steam–gas mixture density at increased pressures is calculated. Based on the experimental data available in the literature, the compressibility factors of H_2, He, N_2, and O_2 gases, and deviations of steam–gas mixture pressure from Dalton's law at the possible parameters of pressurized water reactors are analyzed. It is shown that steam pressure is the key parameter affecting the deviation of steam–water mixture pressure from Dalton's law. The relative value by which the steam–water mixture pressure exceeds the pressure according to Dalton's law increases with a growth of steam pressure and decreases to some extent with a growth of gas temperature and partial pressure. The steam–water mixture model on the basis of a virial equation of state with the use of real compressibility factors of components is implemented in the UROVEN-4 thermal-hydraulic computer code. The analytical model's specific feature is that a multicomponent steam–gas mixture is considered as a binary mixture of steam and noncondensable gas that is a gas mixture composed of four components: N_2, H_2, He, and O_2. The model has been verified for a steam–nitrogen mixture at a steam partial pressure up to 22 MPa, gas partial pressure up to 20 MPa, nitrogen molar fraction equal to 0.11–0.65, and temperature up to 1000 K. It is shown that the analytical model correctly describes the value by which the steam–gas mixture pressure exceeds that according to Dalton's law depending on the steam partial pressure, gas partial pressure, and temperature. The analytical model has been verified against the experimental data for a steam–methane mixture at a steam partial pressure up to 16 MPa under the conditions of saturated and slightly superheated steam, due to which it is possible to forecast the applicability of the model for mixtures with other nonpolar gases: H_2, He, and O_2.

Keywords: noncondensable gas, steam–gas mixture, compressibility factor, deviation from Dalton's law, Amagat's law, Poynting effect

Exergy Analysis of Parabolic Trough Collector

Milind S. Patil[a], *, Sanjay P. Shekhawat[b], Ishan M. Patil[c], Neelkanth G. Nikam[a], and Chandrashekhar D. Mohod[a]

[a] *Guru Gobind Singh College of Engineering and Research Centre, Nashik, 422009 India*

[b] *G H Raisoni College of Engineering & Management, Jalgaon, 425002 India*

[c] *Maratha Vidya Prasarak Samaj's Karmaveer Adv. Baburao Ganpatrao Thakare College of Engineering, Nashik, 422013 India*

**e-mail: mspiso2012@yahoo.com*

Abstract—This work presents an exergetic analysis of the commercial parabolic trough collector (PTC) used for the water desalination that has a dimensions similar to Solar Electric Generating System parabolic trough collector Model LS-2. Exergy analysis focuses on the quality of energy instead of quantity of energy and hence it is more comprehensive than energy analysis for assessing the performance of energy systems. Many researchers focuses on energy analysis and few articles considered the exergy analysis of solar PTC. Hence in this work an Engineering Equation Solver (EES) program was used for the development of the thermal model and exergetic analysis of the solar parabolic trough collector is performed. Heat transfer fluid used for the analysis was Therminol VP-1. Detailed exergetic analysis was presented for various volume flow rate of the Therminol VP-1 and various receiver tube inlet fluid temperature. Thermal model was validated with the published results. It is observed that at inlet fluid temperature 673 K and volume flow rate 200 L/min the exergetic efficiency is 38.5% whereas thermal efficiency is 64.6%. This clearly shows the difference of analysis considering quantity and quality of energy which is the major objective of this study. From the exergy distribution pattern for 25 and 200 L/min volume flow rate, it is concluded at low temperatures lower flow rate of heat transfer fluid are recommended and at high temperatures higher volume flow rate is recommended. For a volume flow rate of 25 L/min useful exergy range is 10 to 30% whereas for volume flow rate of 200 L/min useful exergy range is around 5% to 37%. Also at higher temperature and volume flow rate of a fluid exergy destruction between sun and absorber tube and the total exergy loss is smaller due to lower thermal loss that leads to higher useful exergy.

Keywords: exergy, exergetic efficiency, exergy destruction, solar energy, parabolic trough collector

The Influence of Quantitative and Qualitative Composition of Deposits on the Damageability of High Pressure Boiler Waterwall Tubes

O. V. Egoshina[a, *] and Alkhatib Diaa[a, b]

[a] *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

[b] *Damascus University, Damascus, Syrian Arab Republic*

**e-mail: yegoshinaov@mpei.ru*

Abstract—The operational effectiveness and safety of high-pressure boilers depend on the condition of their heat transfer surfaces. The formation of multilayer deposits on the inner surfaces of waterwall tubes gives rise to problems, especially when there is an impact of steam–water mixture. In carrying out this research, the experiments on studying the composition and structure of deposits were combined with numerical simulation with the aim to quantify the effect of deposits on the temperature distribution in multilayer metal–deposit systems. It has experimentally been found in the course of studies that the deposits form two- and three-layer structures, the thermal conductivity of which varies from 0.37 W/(m · K) for silicate–phosphate layers to 1.5 W/(m · K) for oxide ones. A mathematical model that takes into account a two-phase steam–water flow, multilayer structure of deposits, and temperature dependent properties of materials has been developed and verified. Predictions show that with the working medium density equal to 136 kg/m^3 and contamination equal to 600 g/m^2, the tube temperature may reach 427.5°C, which is by 43°C higher than the critical value for grade 20 steel. The flow velocity ranges and the deposit compositions at which local heating becomes the governing tube damageability factor have been determined. It has been found that there is a linear dependence of the temperature increment on the deposit layer thickness in the range 48–219 μm. The numerical simulation results agree with the experimental data with an rms error of less than 3%. The obtained results open the possibility to develop recommendations on monitoring the water chemistry, forecasting the limit operation conditions, and optimizing the frequency of chemical washing of heating surfaces to prevent waterwall tube damages.

Keywords: thermal power plants, waterwall tubes, steam–water mixture, water chemistry, chemical monitoring, deposits, corrosion, thermal conductivity, two-phase flow

Chemical Blending as a Version for Improving Scale Inhibitors

D. S. Prirez[a, b, *, **] and S. L. Gromov[a]

[a] *National Research University Moscow Power Engineering Institute, Moscow, 111250 Russia*

[b] *Research and Production Company Travers, Moscow, 107564 Russia*

**e-mail: prirez@travers.su*

***e-mail: slgromov@mail.ru*

Abstract—Scaling of slightly soluble compounds is a key problem of water treatment in heat supply and circulation cooling water systems, as well as in the use of membrane technologies. The problem of minimizing the risks of slightly soluble salt scaling on the surface of water treatment or heat transfer equipment is currently solved by metering antiscalants into the water being treated. The performance indicators of such facilities depend not only on the effectiveness of reagents inhibiting the processes through which slightly soluble compounds are crystallized, but also environmental risks associated with their application. Many companies undertake attempts to improve the known reagents and develop so called "green" inhibitors the use of which poses less risks to the environment. The problem of elaborating procedures for evaluating comparative effectiveness of antiscalants without resorting to time-consuming and costly experiments is also of relevance. The article considers an approach to improving the effectiveness based on the antiscalants mixing (blending) method and presents the results of testing some polycarboxylate and phosphorus containing inhibitors of calcium carbonate scaling processes. Based on the studies performed, blended reagents are proposed, and their inhibiting abilities are estimated. It is shown that an antiscalant prepared on the basis of [nitrilotris (methylene)] triphosphonic acid ensures the effectiveness of its use equal to 90% with an active substance dose of around 1.4 mg/dm^3, whereas in the case of using polymers, significantly higher concentrations are required. It has been found that there is a strongly pronounced synergism, i.e., the interaction of two antiscalants, with which their combined use produces an inhibiting effect higher than the sum of effects from each of the components taken separately, for binary and triple compositions with which the required dose of [nitrilotris (methylene)] triphosphonic acid within the composition is four to seven times smaller in comparison with pure phosphonate without loss of effectiveness. The article proposes a mechanism for selectively blocking heterogeneous crystallization nuclei ("nanodust") by antiscalants of various types, which explains the observed synergism.

Keywords: antiscalants blending, scaling of slightly soluble compounds, scale inhibitors, antiscalant, inhibiting effectiveness, water treatment